



GRADATION REPORT

Project: Foothills Silviculture Quality Control

Material Type: 75mm gravel

Sample source/date: Olsen Pit - sampled by Artech July 25, 2012

Specification Limits Shown: MoT Standard Specification. Section 202 Table 202-C.


Lab No: S12-275

Our File: 2012-45

Region: Fernie, BC

Sieve Size	% Passing	Specification	Sieve Size	% Passing	Specification
125			4.75	27.2	20-40
100			2.36	20.2	15-30
75	100	100	1.18	15.1	10-20
37.5	88.8	60-100	0.600	10.6	
19.0	63.1	35-80	0.300	7.1	3-10
12.5	47.2		0.150	5.2	
9.5	40.4	25-60	0.075	3.8	0-5

% PASSING VS GRAIN SIZE



Tested in accordance with ASTM C136, C117 (washed gradation)

Remarks: Spec applied to pit sample from 2012.

Report Date: October 7, 2013

Reports: Foothills Silviculture

c.c:

Per: